



December 11, 2012

Ms. Marcia Gasses
Town Planner & Land Use Administrator
Town of Barrington
PO Box 660
Barrington NH 03825

SUBJECT: Toy Tech – Map 250 Lot 85
Engineering Review Services

Dear Ms. Gasses:

As requested, we have completed our review of the proposed site plan for the above referenced project. Our review services were limited to a review of the stormwater report by Farewell Engineering (dated October 2012) and associated Site Plan (dated November 12, 2012). The following were comments noted during the review.

1. The drainage report did not include an analysis to show that the post development runoff rate does not exceed the pre-development runoff rate in accordance with Article 4.7.1.1 of the Site Plan Review Regulations.
2. The drainage report did not include the information noted in Article 4.7.2 of the Site Plan Review Regulations.

If you should have any questions or comments, please call me.

Very truly yours,
DuBOIS & KING, INC.

A handwritten signature in black ink, appearing to read 'Jeffrey Adler', is written over a faint, circular embossed seal.

Jeffrey A. Adler, P.E.
Senior Project Manager

JAA/js